

CERTIFICATE

Issued to:

Applicant:

Helvar Components Oy Ab
Yrittäjätie 23
03600 Karkkila, Finland

Licensee:

Helvar Components Oy Ab
Yrittäjätie 23
03600 Karkkila, Finland

Product : Electronic controlgear (LED driver)
Trade name(s) : Helvar Components
Type(s)/model(s) : LL35HE-DA-80-400, LL50HE-DA-80-550, LL80HE-DA-100-800 and
LL80HE-DA-150-850

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 4351636


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 16 June 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-159445

DEKRA Certification B.V.

A handwritten signature in blue ink, appearing to read "B.T.M. Holtus".

B.T.M. Holtus
Managing Director

A handwritten signature in blue ink, appearing to read "Miranda Zhou".

Miranda Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic controlgear (LED driver)
Trade name(s)	: Helvar Components
Type(s)/model(s)	: LL35HE-DA-80-400, LL50HE-DA-80-550, LL80HE-DA-100-800 and LL80HE-DA-150-850
Rated voltage	: 220-240 VAC/DC
Rated frequency	: 50-60 Hz
Additional information	: built-in, auto-wound controlgear, non-Inherently short-circuit proof, 120°C thermal protection, EL-mark, EOFi: 0,15;

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 4937215.50,4937215.51.

Additional information

The list of components is laid down in test report 4937215.50.

Conclusion

The examination has confirmed that all requirements were met.

Factory locations

Helvar Components Oy Ab
Yrittäjantie 23
03600 Karkkila, Finland

Trade name : Helvar Components stands for

Helvar
Components