

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear (LED driver)

Name and address of the applicant

Helvar Oy Ab
Yrittäjätie 23, FI-03600 Karkkila
Finland

Name and address of the manufacturer

Helvar Oy Ab
Yrittäjätie 23, FI-03600 Karkkila
Finland

Name and address of the factory

Note: When more than one factory, please report on page 2 Additional information on page 2

Ratings and principal characteristics

Input: 220-240 VAC/DC, 50-60 Hz, built-in, auto-wound controlgear, non-inherently short-circuit proof, 120 °C thermal protection, EL-mark, EOFi: 0,15; Other information refers to model description of test report.

Trademark (if any)

Helvar

Helvar

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LL80HE-DA-150-850, LL80HE-DA-100-800, LL35HE-DA-80-400, LL50HE-DA-80-550

Additional information (if necessary may also be reported on page 2)

This CB Test Certificate is an addition to CB NL-82025 with Test Report Number 4388244.50 dated 2022-07-11 due to the addition of a new model.

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences, EU Special National Conditions

As shown in the Test Report Ref. No. which forms part of this Certificate

4392162.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2022-09-02

Signature: Rosa Zhou

Additional factory

Helvar Oy Ab
Yrittäjätie 23, FI-03600 Karkkila
Finland

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2022-09-02

Signature: Rosa Zhou