

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Independent/built-in LED driver

Name and address of the applicant

Helvar Components Oy Ab
Yrittajantie 23, 03600 Karkkila, Finland

Name and address of the manufacturer

Helvar Components Oy Ab
Yrittajantie 23, 03600 Karkkila, Finland

Name and address of the factory

When more than one factory☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: 220-240 V, Rated emergency range 198-254 Vdc, 50/60 Hz, IP20, ta: 45 °C, tc: 90 °C, SELV, built-in controlgear without cable clamps, independent control gear with cable clamps, constant current output, non-inherently short circuit proof, class II, EL mark. 110 °C thermal protection,

Other information refers to model list of test report for details

Trademark / Brand (if any)



Helvar Components

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LC43MN22-CC-300-1050 and LC43MN22-DA-300-1050

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016

National differences:


EU Group Differences, GB

Comments:

This CB test certificate replaces CB test certificate NL-116615.

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Signature: Miranda Zhou



Date: 2025-05-14

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No.
which forms part of this Certificate

Dated on 2025-05-12 due to typo.

4935744.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-05-14


Signature: Miranda Zhou