

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED module

Name and address of the applicant

Helvar Oy Ab
Keilaranta 5
FI-02150 Espoo
Finland

Name and address of the manufacturer

Helvar Oy Ab
Keilaranta 5
FI-02150 Espoo
Finland

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

220-240V; 0/50-60Hz; constant current 350mA /
25...54V / Prated 18,9W / λ 0,93 or 850mA / 25...42V /
Prated 35,7W / λ 0,96; U-OUT 60V; ta -25...+50°C; tc
+80°C; SELV; DALI; temperature declared 110°C; EL

Trademark (if any)

HELVAR

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

LC35SE-DA-350-850

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61347-2-13:2014
IEC 61347-2-13:2014/AMD1:2016
IEC 61347-1:2015
National Differences:
FI, EU Group Differences
291624-1A

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

SGS Fimko Ltd.
Särkiniementie 3
FI-00210 Helsinki, Finland

SGS

SGS Fimko Ltd.

Date: 2018-12-03

Signature:



Teer Tagers'edt
Certification Manager

Name and address of the factories:

1. Helvar Oy Ab
Yrittäjätie 23
FI-03600 Karkkila
Finland

SGS Fimko Ltd.
Särkiniementie 3
FI-00210 Helsinki, Finland



SGS Fimko Ltd.

Date: 2018-12-03

Signatur :



Teer Tagers'edt
Certification Manager