

CERTIFICATE

Issued to:
Applicant:
Helvar Components Oy Ab
Yrittajantie 23
03600 Karkkila, Finland

Licensee:
Helvar Components Oy Ab
Yrittajantie 23
03600 Karkkila, Finland

Product : LED controlgear
Trade name(s) : Helvar
Type(s)/model(s) : LL50iC-DA-100-1200

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 4351636


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 8 October 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-147696

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K. Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED controlgear
Trade name(s)	: Helvar
Type(s)/model(s)	: LL50iC-DA-100-1200
Rated voltage	: 220-240 VAC/VDC
Rated frequency	: 50-60 Hz
Input current	: 0,23-0,26 A
Max. case temperature (tc)	: 75 °C
Ambient temperature (ta)	: -25- 40 °C
No load voltage	: 60 V
Additional information	: built-in controlgear with double or reinforced insulation without cable clamps, independent control gear with cable clamps, SELV, 120 °C thermal protection, non-inherently short circuit proof;

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 492265700.

Additional information

This certificate replaces certificate No. 35-124595 which we hereby declare invalid.

The list of components is laid down in test report 4922657.50,4922657.51.

Conclusion

The examination has confirmed that all requirements were met.

Factory locations

Helvar Components Oy Ab
Yrittäjätie 23
03600 Karkkila, Finland

Trade name(s) : Helvar stands for

Helvar
Components