



Ref. Certif. No

NO129326

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Driver

Name and address of the applicant

HELVAR OY AB
Yrittajantie 23, 03600 Karkkila
Finland

Name and address of the manufacturer

HELVAR OY AB
Yrittajantie 23, 03600 Karkkila
Finland

Name and address of the factory

See next page(s)

Note: When more than one factory, please report on page 2

 Additional Information on Page 2

Ratings and Principal characteristics

LV supply:
PRI: max. 0.3 A, 220-240 V~, 50/60 Hz
SEC: Max. 42.0 W, max. 1.05 A, 9-48 Vd.c. (under load),
max. 60 Vd.c. (no-load).
Centralized emergency power supply: 198-254 V dc

Trademark /Brand (If any)

Customer's Testing Facility (CTF) Stage used

Model/Type Ref

LC43MINI-CC-300-1050-B, LC43MINI-CC-300-1050

Additional information (If necessary may also be reported on Page 2)

 Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP024672

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 30-01-2024Signature: Yasaman Vadoudi
Certification department



Ref. Certif. No

NO129326

Additional Information (if necessary)

Independent type with terminal cover incl. strain relief, Class II;

Built-in type without terminal cover.

EOFI: 15%, SELV, constant current output, thermal protected 110 °C, ta: 40 °C / 45 °C, tc: 80 °C



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 30-01-2024

A handwritten signature in black ink that reads 'Yasaman Vadoudi'.

Signature: Yasaman Vadoudi
Certification department