

ATTESTATION OF CONFORMITY

Issued to: Helvar Oy Ab
Yrittäjätie 23, FI-03600 Karkkila, Finland

For the product: Electronic control gear for LED module

Trade name: Helvar

Type/Model: LC45SE-DA-600-1050-LOOP, LC51SE-DA-900-1400-LOOP

Ratings: Input: 220-240 Vac, 0/50-60 Hz
LC45SE-DA-600-1050-LOOP Output:
600 mA, 25-54 Vdc, 1050 mA, 25-42,8 Vdc;
LC51SE-DA-900-1400-LOOP Output:
900 mA, 25-54 Vdc, 1400 mA, 25-36,4 Vdc;

Manufactured by: Helvar Oy Ab
Yrittäjätie 23, FI-03600 Karkkila, Finland

Requirements: EN 301 489-1 V2.2.3:2019-11 EN 301 489-3 V2.1.1:2019-03
EN 300 330 V2.1.1:2017-02 EN IEC 55015:2019 + A11:2020
EN 61547:2009 EN IEC 61000-3-2:2019 + A1:2021
EN 61000-3-3:2013 + A1:2019 + A2:2021 EN 50665:2017
EN 61347-1:2015 EN 61347-2-13:2014 + A1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 438831800.

This Attestation implies that the examined types are in accordance with the standards designated under the Radio Equipment Directive (RED) 2014/53/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 6 July 2022

Number: 4388318.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou Branch



Miranda Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed