

Ref. Certif. No.

NL-117435

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

When more than one factory

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Electronic controlgear (LED driver)

Helvar Components Oy Ab Yrittajantie 23, 03600 Karkkila, Finland

Helvar Components Oy Ab Yrittajantie 23, 03600 Karkkila, Finland

☑ Additional information on page 2

Product data Ratings: Input: 220-240 VAC/DC, 50-60 Hz, built-in, auto-wound controlgear, non-Inherently short-circuit proof, 120°C thermal protection, EL-mark, EOFi: 0,15; Other information refers to model description of test report.



LL35HE-DA-80-400, LL50HE-DA-80-550, LL80HE-DA-100-800 and LL80HE-DA-150-850

□ Additional information on page 2

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016

National differences: AU, EU Group Differences, GB, NZ

4937215.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051 6825 MJ Arnhem Netherlands

Mugl



Signature: May Liu

Page 1 of 2

Date: 2025-06-16



Ref. Certif. No.

NL-117435

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Additional factory

Helvar Components Oy Ab Yrittajantie 23, 03600 Karkkila, Finland

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051 6825 MJ Arnhem Netherlands

Mugl

Signature: May Liu



Date: 2025-06-16

E May Liu